



PLEASE NOTE:  
 1. WET WELLS ARE AVAILABLE IN 48", 60", AND 72" DIAMETERS.  
 2. HEAVY DUTY (300 PSF) ALUMINUM HATCH COVERS ARE AVAILABLE ON REQUEST.  
 3. VALVE BOX DIMENSIONS CAN VARY TO MEET JOB SPECIFICATIONS

- GENERAL NOTES:
1. ALL CONCRETE SHALL HAVE A MIX DESIGN OF 5000 PSI WITH A MINIMUM OF 5 SACKS OF STANDARD TYPE 1 CEMENT.
  2. ALL REINFORCING BARS SHALL BE CLEAN, NEW AND FREE OF DIRT, RUST, OR OIL AND SHALL MEET OR EXCEED THE REQUIREMENTS OF ASTM A-615M, GRADE 60
  3. WELDED WIRE FABRIC SHALL BE CLEAN, NEW AND FREE OF DIRT, RUST, OR OIL AND SHALL MEET OR EXCEED THE REQUIREMENTS OF ASTM A-185.
  4. LAP REBARS AT ALL SPLICES A MINIMUM OF 36 BAR DIAMETERS LAP WIRE AT ALL SPLICES A MINIMUM OF 40 DIAMETER OF THE COLD-DRAWN WIRE.
  5. ALL REINFORCING SHALL BE SET AND TIED, ALL CONCRETE SHALL BE PLACED, FINISHED, AND CURED PER ACI 318-83 SPECIFICATIONS AND PER ALL SAFETY PROVISIONS OF OSHA.
  6. WALL AND BOTTOM REINFORCING OF THE STRAIGHT WALL STRUCTURES SHALL BE NO. 4 BAR ON 12" CENTER TO CENTER.
  7. TOP REINFORCING SHALL BE NO. 6 BAR ON 6" CENTER TO CENTER SPACED 2" FROM BOTTOM SURFACE OR EQUAL.
  8. WALL REINFORCING ON ROUND STRUCTURES SHALL MEET ASTM 478-93 REQUIREMENTS (STANDARD SPECIFICATION FOR PRECAST REINFORCED CONCRETE MANHOLE SECTIONS).
  9. MANUFACTURER RESERVES THE RIGHT TO MAKE CHANGES WHENEVER NECESSARY.

## WET WELLS

WALLIS CONCRETE, INC.

P.O. BOX 789  
 WALLIS, TEXAS 77485

PHONE: (800) 852-7880  
 FAX: (979) 478-6753